

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main Street, PO Box 235
Delanson, New York 12053

Period of February 1, 2015 – February 28, 2015

Total Amount of Water Used per Period:	947,000 gals.
Average Amount of Water Used per Day:	34,000 gals.
Total Amount of Hypochlorite Used per Period:	27 gals.
Average Amount of Hypochlorite Used per Day:	1 gal.

Tuesday, February 3, 2015:

- * Sent monthly operational reports to Schenectady Co.

Wednesday, February 4, 2015:

- * Met with Gayle concerning 2015-2016 budget estimates

Tuesday, February 10, 2015:

- * Copied on an email from Ron Holbrook concerning damage to his mailbox (Stewart Lane).

Thursday, February 12, 2015:

- * Cancelled scheduled hydrant flushing for Sat. Feb. 14th due to weather conditions. Re-scheduled for Sat. Feb. 21st. Gayle will make proper notifications.

Wednesday, February 18, 2015:

- * Email from Amy Bruce (Newton St.) asking about hydrant on Newton St.
- * Call from Pat Scalera (NYRWA) Discussion of the possibility of me attending Congressional forum related to challenges facing small water systems.

Thursday, February 19, 2015:

- * Cancelled re-scheduled hydrant flushing for Sat. Feb 21st due to weather conditions to Sat. Feb. 28th. Gayle will make proper notifications.
- * Email response to Amy Bruce
- * Steve and I responded to a complaint of no water at Rice residence on East Shore Rd. Determined that the service line was frozen between the home and the shut-off valve, therefore the responsibility of the homeowner.

Friday, February 20, 2015:

- * Conversation with Pat Scalera (NYRWA) Congressional forum scheduled for next Thursday.

Monday, February 23, 2015:

- * Conversations with Pat Scalera and Josh regarding participation in Congressional forum.

Tuesday, February 24, 2015:

- * Met with Molly Reed (NYRWA).

Wednesday, February 25, 2015:

- * Complaint of no water from Audra Oldorf (Elm St.)
- * Complaint of no water at Rice residence (East Shore Rd.)
- * Highway Dept. cleared snow from hydrant on Newton St.

Thursday, February 26, 2015:

- * Sent monthly bacti sample to JH Consulting
- * Complaint of no water on Charles St. (Boggs & Compton)
- * Cancelled hydrant flushing scheduled for Sat. Feb 28th. Gayle will proper notification

Friday, February 27, 2015:

- * Steve and I worked on thawing Charles St. water line

Saturday, February 28, 2015:

- * Steve and I worked on thawing Charles St. water line