

Jeffrey A. Iveson  
Water Commissioner, Village of Delanson  
1797 Main St., PO Box 235  
Delanson, New York 12053

---

**October 1, 2017 – October 31, 2017**

Total Amount of Water Used per Period:	1,003,000 gals.
Average Amount of Water Used per Day:	32,000 gals.
Total Amount of Hypochlorite Used per Period:	45 gals.
Average Amount of Hypochlorite Used per Day:	1.45 gals.

Monday, October 2, 2017:

- \* Attended Village Board meeting
- \* Telephone call from Dominick DiCarlo, Co. DOH, regarding TTHM & HAA5 violations

Tuesday, October 3, 2017:

- \* Responded to mark out request for Quaker Lane on DigSafely website
- \* Left telephone message for Francois at Lamont Engineers

Wednesday, October 4, 2017:

- \* Received email confirmation from Isabelle that the “No Trespass” signs have been ordered
- \* Sent completed September water report to Isabelle

Tuesday, October 10, 2017:

- \* Responded to mark out request at 565 Knight Rd. (Bellville) for installation of new foundation, septic system, well line and electrical line

Thursday, October 12, 2017:

- \* Meeting with Lamont Engineering
- \* Email from Dante at the Y regarding discolored water and questions regarding TTHM notification

Tuesday, October 17, 2017:

- \* Lead & Copper test results from JH Consulting
- \* Disconnection permit issued by Gayle to Aanen for work at school
- \* Text to Gayle and Josh about meeting with Lamont Engineering

Wednesday, October 18, 2017:

- \* Took water sample at Y. Chlorine residual = .36 Turbidity = 1.01
- \* Picked up signs and posts at Isabelle's
- \* Draining filter bed #1
- \* Called Francois to let him know that the November Village Board meeting is Monday, November 6<sup>th</sup> @ 7PM
- \* Submitted IOC/VOC, nitrate and monthly bacti samples to JH Consulting
- \* Aanen called to let me know that the water should not be turned off yet at the school because Plank Construction was using it to mix concrete. Aanen will contact me when he wants it turned off

Monday, October 23, 2017:

- \* Steve and I cleaned filter bed #1
- \* Meeting with Gayle and Donna Shave to redraw the Villages area of notification for DigSafely
- \* Hoist not working correctly. Will contact All-Lifts

Tuesday, October 24, 2017:

- \* Called All-Lifts. They will check into warranty coverage on the hoist,
- \* Gayle texted to confirm that the changes on the DigSafely mapping were correct

Thursday, October 26, 2017:

- \* All-Lifts called to say hoist is still under warranty and they will schedule a pick-up for repair
- \* Responded to mark out request at 7082 Western Turnpike for installation of new driveway and parking lot

Monday, October 30, 2017:

- \* Water turned off at house at corner of Alexander Rd (per Gayle)
- \* Received VOC results

Tuesday, October 31, 2017:

- \* All-Lifts picked up the hoist for service

---

**THIS IS AN EQUAL OPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED BY FEDERAL LAW. COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14<sup>TH</sup> & INDEPENDENCE AVE., SW, WASHINGTON, D.C. 202500410 (518)895-2100 TDD#1-800-662-1220**