

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1707 Main Street P.O. Box 235
Delanson, New York 12053

Period of June 1, 2013 – June 30, 2013

Total Amount of Water Used per Period:	1,085,000 gals.
Average Amount of Water Used per Day:	36,000 gals.
Total Amount of Hypochlorite Used per Period:	40.75 gals.
Average Amount of Hypochlorite Used per Day:	1.35 gals.

Monday, June 3, 2013:

- * Received quarterly TTHM & HAA5 sample results. Both are in compliance.

Tuesday, June 4, 2013:

- * Met Dom DiCarlo at the plant for him to perform radium sampling. No cost to the Village, which is a huge cost savings for the Village.
- * Sent monthly operational reports to Schenectady DOH

Thursday, June 6, 2013

- * Ordered chlorine and zinc

Wednesday, June 12, 2013:

- * Met driver when chemicals were delivered at the plant. Door closure arm was broken.

Tuesday, June 18, 2013:

- * Received call from DACC concerning pool filling. They would like to fill July 3rd and 4th

Thursday, June 20, 2013:

- * Sent monthly bacti sample to JH Consulting

Friday, June 21, 2013:

- * Steve and I cleaned filter bed #3

THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED BY FEDERAL LAW. COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14TH AND INDEPENDENCE AVE. SW, WASHINGTON, D.C. 202500410 (518)895-2199 TD# 1-800-662-1220