

Jeffrey A. Iveson  
Water Commissioner, Village of Delanson  
1797 Main Street P.O. Box 235  
Delanson, New York 12053

---

**Period of May 1, 2013 – May 31, 2013**

Total Amount of Water Used per Period:	1,146,000 gals.
Average Amount of Water Used per Day:	37,000 gals.
Total Amount of Hypochlorite Used per Period:	38.5 gals.
Average Amount of Hypochlorite Used per Day:	1.24 gals.

Wednesday, May 1, 2013:

- \* Steve and I cleaned filter bed #1
- \* Clearwells dropped; will keep track of daily totals, may have break

Thursday, May 2, 2013:

- \* Discussed hydrant flushing date with Gayle. Will flush on Saturday, May 11<sup>th</sup>. Gayle will include flushing notice in Village Newsletter

Monday, April 6, 2013:

- \* Submitted monthly operational reports to Schenectady Co. DOH

Thursday, May 09, 2013:

- \* Received copy of renewal notice for Annual Highway Work Permit from NYS DOT
- \* Contacted Steve Winkley (NYRWA) about updating water system mapping

Saturday, May 11, 2013:

- \* Steve and I flushed hydrants. Noticed high water usage. Determined problem was near school. No luck reaching Aanen. Flushed main line only, so that quarterly samples can be taken on Monday.

---

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED BY FEDERAL LAW. COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14<sup>TH</sup> AND INDEPENDENCE AVE. SW, WASHINGTON, D.C. 202500410 (518) 895-2199 TDD#1-800-662-1220**

Monday, May 13, 2013:

- \* TTHM & HAA5 samples taken
- \* Several conversations with Gayle & Josh concerning the possible need repair leak near school.
- \* Spoke with Aanen. RPZ at school is malfunctioning. Aanen will order re-build kit. Advised Brenda Kane that RPZ will need to be re-inspected after it is repaired.
- \* Problem with account at HD Works
- \* Second call to LaMotte regarding 3000we

Friday, May 24, 2013:

- \* Steve and I cleaned filter bed #3
- \* Aanen still waiting for re-build kit.

Tuesday, May 28, 2013:

- \* Left third message at LaMotte for Tim. Spoke with Charlie
- \* Completed USDA survey regarding filtration plant
- \* Spoke with Steve Winkley (NYRWA). He will contact County about updated GIS info for water system mapping. (Will require Village OK)

Wednesday, May 29, 2013:

- \* Call from Dominick DiCarlo. County will perform radium testing, at no charge, on Tuesday, June 4