

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main Street P.O. Box 235
Delanson, New York 12053

Period of April 1, 2013 - April 30, 2013

Total Amount of Water Used per Period:	967,000 gals.
Average Amount of Water Used per Day:	37,000 gals.
Total Amount of Hypochlorite Used per Period:	22 gals.
Average Amount of Hypochlorite Used per Day:	.61 gals.

Monday, April 1, 2013:

- * Prepared and submitted monthly operational reports for Sch. Co.

Tuesday, April 2, 2013:

- * Chlorine/turbidimeter sent to LaMotte Co. for repair

Monday, April 8, 2013:

- * Steve and I attended Village Board meeting
- * Signed Oath of Office book

Tuesday, April 9, 2013:

- * LaMotte rep. called. First meter sent for repair will cost \$75. to repair. (Needs on/off switch & a connection soldered)
- * Call from Aanen, for a mark-out at school. (School installing solar panels)
- * Provided copies of Village Emergency Plan & Vulnerability Assessment to Mayor Gifford

Wednesday, April 11, 2013:

- * Provided Watershed Rules and Regulations for Mayor Gifford

Friday, April 12, 2014:

- * Contacted Josh about the Watershed Rules and Regulations
- * Schenectady Co. Department of Public Works called for a mark-out at the McMillan Well

THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED BY FEDERAL LAW. COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14TH AND INDEPENDENCE AVE. SW, WASHINGTON, D.C. 20250-0410 (518) 895-2100 TDD#1-800-662-1220

Monday, April 15, 2013:

- * Steve and I cleaned filter bed #2
- * Marked out the McMillan Well for Schenectady Co. guard rail project

Tuesday, April 16, 2013:

- * Call from LaMotte Co. There will be no charge for the repair of the second meter sent for repair.

Thursday, April 18, 2013:

- * Monthly bacti sample sent to JH Consulting
- * First meter returned