

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main Street, P.O. Box 235
Delanson, New York

Period of July 1, 2013 - July 31, 2013

Total Amount of Water Used per Period:	1,364,000 gals.
Average Amount of Water Used per Day:	44,000 gals.
Total Amount of Hypochlorite Used per Period:	66.0 gals.
Average Amount of Hypochlorite Used per Day:	2.14 gals.

Wednesday, July 3, 2013:

- * Sent monthly operational reports to Schenectady Co. DOH

Friday, July 6, 2013:

- * DACC used 60,000 gals. of water for the pool fill. Gayle will handle the billing. (Remote read not working properly.)

Monday, July 8, 2013:

- * Attended Village Board meeting.
- * Spoke to Aanen. Repair to RPZ has not been made.

Wednesday, July 10, 2013:

- * Spoke with Gayle. She is getting quotes for repair of the phone line at the plant

Thursday, July 11, 2013:

- * Spoke to Gayle . Decided to stay with AT&T for the plant phone. Basic service is \$27. /month.

Monday, July 15, 2013:

- * Had a telephone call from Gayle concerning the newsletter! flushing date

Tuesday, July 16, 2013:

- * Returned Gayle's call. Hydrant flushing will be on Saturday, Aug. 17~

Wednesday, July 17, 2013:

- * Call from Terry Lindh concerning water problem at brown rental property on lower East Shore Rd. Determined the water to be ground be ground water.
- * Terry asked when repair to the mower damaged shut-off valves would accomplished. Told him that it would be done when the heat breaks.

Thursday, July 18, 2013:

- * Sent monthly bacti samples to JH Consulting

Monday, July 22, 2013:

- * Call from Gayle concerning the school moving the portable classroom, and the trailer's effect on the water shut-offs.
- * Called Aanen, who was very uncooperative. Said that the company performing the removal must have good insurance, and could take care of whatever happened.
- * Also said that he wanted to remove the copper service lines. Told him that he MUST have a permit and inspection
- * Aanen said that he will find a new installer for the RPZ. (Original installer is ill, and will not be able to complete the work)
- * Steve Winkley emailed that he has sent two duplicate CD's that contain revised water system mapping to the Village. Also said that he would willing to come out to install! show how it works

Wednesday, July 24, 2013:

- * Call from Josh O'Connor. Said that his father has low water pressure in his upstairs.
- * Took various pressure readings within the Village. Pressure at firehouse 70psi. No other calls of low pressure.

Saturday, July 27, 2013:

- * Steve and I cleaned filter bed #3

Monday, July 29, 2013:

- * Gayle called to confirm tomorrow's meeting with Steve Winkley
- * Spoke to Josh, and offered to take pressure readings at Larry's home. Josh said that he would let me know if that was necessary.

Tuesday, July 30, 2013:

- * Met with Steve Winkley, Josh and Gayle concerning the revised mapping for the water program

THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED BY FEDERAL LAW. COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14TH AND

INDEPENDENCE AVE., SW, WASHINGTON, D.C. 20250-0410 (518) 895-2199
TDD# 1-800-662-1220