

Jeffrey A. Iveson  
Water Commissioner, Village of Delanson  
1797 Main Street PO Box 235  
Delanson, New York 12053

---

Period of December 1, 2013 - December 31, 2013

Total Amount of Water Used per Period: 1.090,000 gals.  
Average Amount of Water Used per Day: 35,000 gals.  
Total Amount of Hypochlorite Used per Period: 25.25 gals.  
Average Amount of Hypochlorite Used per Day: .81 gals.

For clarification purposes: Conversation with DOH concerning chlorine reduction in the clearwells occurred on/about November 15, 2013, with implementation of recommendations immediately following.

Wednesday, December 4, 2013:

- \* Received 4th quarter TTHM &HAA5 sample results.  
TTHM (MCL=80) =53  
HAA5 (CL=60) = 37
- \* Sent monthly operational reports to Co. DOH

Monday, December 9, 2013:

- \* Attended Village Board meeting
- \* Received thank you e-mail from Pat Scalera for sending estimated inventory losses due to implementation of No Lead Law

Wednesday, December 11, 2013:

- \* Steve and I cleaned filter bed #2. ( Omitted from Nov. 2013 report: Steve and I cleaned filter bed #1 on Nov. 29)
- \* Sent monthly bacti, nitrite and nitrate samples to JH Consultants

Wednesday, December 18, 2013:

- \* Responded to a request from Bucky Grenier to turn off water at his residence, to allow for repair of valve in his basement. Service restored after repair.

Tuesday, December 24, 2013:

- \* Email notification from NYRWA that on Dec. 20, 2013 the President signed into law the "Community Fire Safety Act of 2013" which exempts fire hydrants from the Safe Drinking Water Act lead level standards for pipe, fittings, fixtures, solder and flux.

Thursday, December 26, 2013:

- \* Changed UV bulbs, pulled duty sensor and compared to reference sensors.