

Jeffrey A, Iveson
Water Commissioner, Village of Delanson
1797 Main Street PO Box 235
Delanson, New York 12053

Period of June 1, 2014 – June 30, 2014

Total Amount of Water Used per Period:	1,158,000 gals.
Average Amount of Water Used per Day:	38,000 gals.
Total Amount of Hypochlorite Used per Period:	51.25 gals.
Average Amount of Hypochlorite Used per Day:	1.7 gals.

Tuesday, June 3, 2014:

- * Sent monthly reports to Schenectady Co. DOH
- * Received email from Dig Safely member support. Additional paperwork must be filed to complete the Villages' registration
- * Call from Gayle. She had a call from Larry Grygas regarding low water at his East Shore Rd. home. I had been called back to work to repair storm damage from this afternoons storms. Steve checked pressure at firehouse (70psi). No other reports of pressure problems had been received,
- * Received VOC sample results from JH Consulting

Wednesday, June 4, 2014:

- * Received TTHM & HAA5 2nd quarter sample results from JH Consulting (TTHM=74.3 HAA5=55.2)
- * Spoke to Larry Grygas regarding pressure issue. He stated that he had determined that the problem was a plugged shower head. Telephoned Gayle to let her know the outcome of our conversation.
- * Received Inorganic Chemical sample results from JH Consulting
- * Emailed May water report to Village Clerk

Monday, June 9, 2014:

- * Attended Village Board meeting

Wednesday, June 11, 2014:

- * Sent monthly bacti sample to JH Consulting

Thursday, June 19, 2014:

- * Email from Dig Safely Customer Service Dept. inquiring if any assistance was needed in completing mapping . Josh and Gayle indicated earlier this month that they will complete the mapping.

Monday, June 23, 2014:

- * Marked out water line at Tarmeys, Stewart Lane
- * Inspection at Upper Reservoir

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED.
COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF
CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14TH & INDEPENDENCE AVE. SW,
WASHINGTON, D.C. 202500410 (518) 895-2100 TDD# 1-800-662-1220**