

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main Street PO Box 235
Delanson, New York 12053

Period of August 1, 2014 – August 31, 2014

Total Amount of Water Used per Period:	1,230,000 gals.
Average Amount of Water Used per Day:	39,000 gals.
Total Amount of Hypochlorite Used per Period:	75 gals.
Average Amount of Hypochlorite Used per Day:	1.95 gals.

Wednesday, August 6, 2014:

- * Sent monthly operational reports to Schenectady Co. DOH

Thursday, August 7, 2014:

- * Sent monthly report to Board to Village Clerk

Saturday, August 9, 2014:

- * Steve and I flushed hydrants

Monday, August 11, 2014:

- * Attended Village Board meeting
- * Sent quarterly TTHM &HAA5 samples to JH Consulting, as well as Lead samples
- * Trustees will contact me on Sun. to set up a trip to the Upper Reservoir

Wednesday, August 27, 2014:

- * Received lead and copper sample results from JH Consulting

Friday, August 29, 2014:

- * Steve located a break. Began repair at 2:30 PM and completed it at approx. 9:30 P.M.

THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED BY FEDERAL LAW. COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14TH & INDEPENDENCE AVE. SW, WASHINGTON, D.C. 202500410 (518) 895-2199 TDD# 1-800-662-1220