

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main Street PO Box 235
Delanson, New York 12053

Period of September 1, 2014 – September 30, 2014

Total Amount of Water Used per Period:	1,222,000 gals.
Average Amount of Water Used per Day:	40,000 gals.
Total Amount of Hypochlorite Used per Period:	54 gals.
Average Amount of Hypochlorite Used per Day:	1.8 gals.

Tuesday, September 2, 2014:

* Received quarterly TTHM & HAA5 results. TTHM=75.73 HAA5=31.78

Thursday, September 4, 2014:

* Sent monthly operational reports to Schenectady Co. DOH

Monday, September 8, 2014:

* Attended Village Board meeting. Board approved Water Dept. rental of equipment for bollard and light installation at plant.

Wednesday, September 10, 2014:

* Draining down filter bed #1

Friday, September 12, 2014:

* Steve and I cleaned filter bed #1

Wednesday, September 17, 2014:

- * Sent monthly bacti sample to JH Consulting
- * Spoke with Tim O'Brien (Harvest Homes). He stated that he had called the Mayor about traffic on the road, not water quality. Said he hadn't called about water quality in over 1-1/2 to 2 years. Gave him some pointers about flushing his system after hydrant flushing
- * Gayle located picture frames in the storage closet, so I replaced the broken one around license in plant.
- * Made arrangements for generator service at plant and fire house. Also requested quote for relocation of fire house generator to rear of building

Wednesday, September 22, 2014:

* First call at 6:30 AM from East Shore Rd. concerning no water. Found break behind Matt Grenier's house on Main St. System pressure did not recover after repair. Found second break along Rte. 395, across

the street from the High School. Steve and I worked from 6:30 AM – 1 AM.

Saturday, September 25, 2014:

- * Draining down filter bed #3

Monday, September 29, 2014:

- * Received Dig Safely request for mark out at 518 East Shore Rd.
- * Steve and I cleaned filter bed #3
- * Generators at the plant and the fire house were serviced

Tuesday, September 30, 2014:

- * Received Dig Safely request for mark out at Our Lady of Fatima
- * Responded to both mark out sites.

THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED BY FEDERAL LAW. COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14TH & INDEPENDENCE AVE. SW, WASHINGTON, D.C. 202500410 (518) 895-2100 TDD# 1-800-662-1220