

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main Street PO Box 235
Delanson, New York 12053

Period of November 1, 2014 – November 30, 2014

Total Amount of Water Used Per Period:	984,000 gals.
Average Amount of Water Used Per Day:	33,000 gals.
Total Amount of Hypochlorite Used Per Period:	39 gals.
Average Amount of Hypochlorite Used Per Day:	1.3 gals.

Monday, November 3, 2014:

- * Attended Village Board meeting
- * Emailed report to Village Board to Clerk
- * Posted hydrant flushing info on sign at firehouse

Tuesday, November 4, 2014:

- * Sent monthly operational reports to Schenectady Co. DOH

Saturday, November 8, 2014:

- * Steve and I flushed hydrants. Met with Bucky and Josh to tour plant and Upper Reservoir

Monday, November 10, 2014:

- * Sent quarterly TTHM & HAA5 samples and monthly bacti sample to JH Consulting

Wednesday, November 12, 2014:

- * Draining down filter #1

Friday, November 13, 2014:

- * Steve and I cleaned filter bed #1

THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED BY FEDERAL LAW. COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14TH & INDEPENDENCE AVE. SW, WASHINGTON, D.C. 202500410 (518) 895-2199 TDD# 1-800-662-1220