

Jeffrey A. Iveson  
Water Commissioner, Village of Delanson  
1797 Main Street, PO Box 235  
Delanson, New York 12053

---

**Period of December 1, 2014 – December 31, 2014**

Total Amount of Water Used per Period:	1,270,000 gals.
Average Amount of Water Used per Day:	41,000 gals.
Total Amount of Hypochlorite Used per Period:	34 gals.
Average Amount of Hypochlorite Used per Day:	1.5 gals.

Thursday, December 4, 2014:

- \* Sent monthly operational reports to Schenectady Co.
- \* Sent monthly report to Board to Village Clerk
- \* Met telephone guy at the plant

Thursday, December 11, 2014:

- \* Water usage up. Called NYRWA for assistance. Rich Winters located break near Verizon building

Friday, December 12, 2014 – Friday, December 19, 2014:

- \* Repaired series of breaks near Verizon building

Monday, December 22, 2014:

- \* Filter bed #2 was cleaned
- \* Met with Gayle and PESH representative

Tuesday, December 23, 2014:

- \* Sent monthly bacti sample to JH Consulting

---

**THIS IS AN EQUAL OPPORTUNITY PROGRAM, DISCRIMINATION IS PROHIBITED BY FEDERAL LAW. COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14<sup>TH</sup> AND INDEPENDENCE AVE, SW, WASHINGTON D.C. 202500410 (518) 895-2100 TDD# 1-800-662-1220**