

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main Street, PO Box 235
Delanson, New York 12053

Period of May 1, 2015 – May 31, 2015

Total Amount of Water Used per Period:	1,275,000 gals.
Average Amount of Water Used per Day:	41,000 gals.
Total Amount of Hypochlorite Used per Period:	29.25 gals.
Average Amount of Hypochlorite Used per Day:	.94 gals.

Monday, May 4, 2015:

- * Called Jim Donelly about proposed driveway at Rosasco property
- * Sent copy of December 2014 water report to Village Clerk

Wednesday, May 6, 2015:

- * Spoke to Dom DiCarlo about May 12th meeting with NYSDOH
- * Sent monthly operational reports to Schenectady Co.

Thursday, May 7, 2015:

- * Met with Gayle concerning FEMA projects

Saturday, May 9, 2015:

- * Steve and I flushed hydrants .
- * Repaired shut offs at DeMarco-Stone and Mark Clemons residences.
- * Hydrant damage on West Shore Rd. (Lock filled with silicone)

Monday, May 11, 2015:

- * Attended Village Board meeting

Tuesday, May 12, 2015:

- * Met with County and State Department of Health officials to discuss TTHM and HAA5 status/progress

Thursday, May 14, 2015:

- * Dig Safely markout request from NYSDOT for Route 395 near Cooley Heights

Tuesday, May 19, 2015:

- * Email request from Mike Davis concerning transmission line located between Delevan Rd. and Mudge Rd.

Thursday, May 28, 2015:

- * Dig Safely request from Charlie Rhoades concerning constructing of driveway and culvert on Alexander Rd.
- * Sent monthly bacti report to Schenectady Co. DOH

THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED BY FEDERAL LAW. COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14TH AND INDEPENDENCE AVE. SW, WASHINGTON, D.C. 202500410 (518) 895-2199 TDD# 1-800-662-1220)