

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main Street, PO Box 235
Delanson, New York 12053

Period of June 1, 2015 – June 30, 2015

Total Amount of Water Used per Period:	1,053,000 gals.
Average Amount of Water Used per Day:	35,000 gals.
Total Amount of Hypochlorite Used per Period:	38.5 gals.
Average Amount of Hypochlorite Used per Day:	1.28 gals.

Wednesday, June 3, 2015:

- * Dig Safely request for markout at DCS for soil borings by Aquifer Drilling & Testing Inc.

Thursday, June 4, 2015:

- * Response to Joe Miranda (Aquifer Drilling & Testing Inc.)
- * Sent monthly report to Village Board to Village Clerk

Monday, June 8, 2015:

- * Attended Village Board meeting

Wednesday, June 10, 2015:

- * Contacted Customer Support team for Dig Safely email response training
- * Had a call from a resident on Stewart Lane, reporting standing water in a neighbors yard. Spoke to homeowner and found that the problem was the result of a malfunctioning cellar sump pump.

Wednesday, June 25, 2015:

- * Spoke with Aanen at DCS. Schools' RPZ had failed inspection. School wanted to replace it with a check valve. I stated that a check valve was inadequate. Aanen said that the schools' engineer had said a check valve was adequate. I confirmed with Co. DOH that a RPZ was required, and forwarded that info to Aanen.

Thursday, June 26, 2016:

- * Call from Dante at DACC. Said that they were doing work in the pool, and would like to purchase water from the Village when the pool was refilled. Spoke to Gayle who verified the price per gallon (3 cents/gal.) She will respond to Dante, and let him know that we will need 2 weeks notice to assure that the filter beds are all clean

* Sent monthly bacti sample to JH Consultants.

Friday, June 27, 2015:

* Spoke to rep from USA Bluebook about a multi-function valve

Monday, June 29, 2015:

* Steve and I responded to 3 mark out requests from DigSafelyny (Post Office, Powles and Thousand Acre Rd.)

THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED BY FEDERAL LAW. COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF CIVIL RIGHTS, ROOM 326, WHITTEN BUILDINGM 14TH & INDEPENDENCE AVE., SW, WASHINGTON, D.C. 202500410 (518)895-2100 TDD# 1-800-662-1220