

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main Street PO Box 235
Delanson, New York 12053

Period of October 1, 2015 – October 31, 2015

Total Amount of Water Used per Period:	954,000 gals.
Average Amount of Water Used per Day:	30,000 gals.
Total Amount of Hypochlorite Used per Period:	50 gals.
Average Amount of Hypochlorite Used per Day:	1.6 gals.

Thursday, October 1, 2015:

- * Looked for break that Carver Construction told Gayle was near Verizon building on Main Street. (Didn't find anything. No excessive water usage recorded at plant. No complaints from residents.) Gayle not satisfied with my findings. Will contact NYRWA for a "second opinion"

Friday, October 2, 2015:

- * NYRWA came out to look for leak near Verizon building. Found none.

Monday, October 5, 2015:

- * Attended Village Board meeting
- * DEC to inspect dams on Thursday, October 8th
- * Responded to Dig Safely mark out request at 2002 Main Street for the construction of a retaining wall

Thursday, October 8, 2015:

- * Responded to Dig Safely mark out request at Railroad Ave
- * Telephone call with Dan Lindh regarding water hook-up fees

Monday, October 12, 2015:

- * Responded to mark out request on Mudge Road for a culvert replacement

Wednesday, October 14, 2015:

- * Sent monthly bacti sample and annual IOC/VOC samples to JH Consulting

Wednesday, October 21, 2015:

- * Straightened out shipping problem with USA Blue Book
- * Received report from DEC dam inspection

Monday, October 26, 2015:

- * Call from Kevin that Empire Paving had used water from hydrant at Fire Hall. No complaints from residents regarding either low pressure or discoloration. Attempted to speak to job foreman about the incident but he was not present at job site. Padlocked hydrant for short-term fix, until Board makes decision on whether or not additional hydrant locks should be purchased.

Tuesday, October 27, 2015:

- * Steve and I cleaned filter bed #3.

