

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main Street, PO Box 235
Delanson, New York 12053

Period of December 1, 2015 – December 31, 2015

| | |
|---|---------------|
| Total Amount of Water Used per Period: | 994,000 gals. |
| Average Amount of Water Used per Day: | 32,000 gals. |
| Total Amount of Hypochlorite Used per Period: | 32.5 gals. |
| Average Amount of Hypochlorite Used per Day: | 1.48 gals. |

Tuesday, December 1, 2015:

- * Sent monthly operational reports to Schenectady Co. DOH
- * Received quarterly TTHM & HAA5 results

Wednesday, December 2, 2015:

- * Responded to DigSafelyNY mark out request at Myles Peterson home on Main Street

Thursday, December 3, 2015:

- * Spoke with Dante at DACC regarding exterior water meter replacement
- * Draining filter bed #1

Sunday, December 6, 2015:

- * Steve and I cleaned filter bed #1

Thursday, December 10, 2015:

- * Paving contractor performing work at Post Office using water from hydrant. Gayle spoke to them.
- * Draining filter bed #3

Sunday, December 19, 2015:

- * Steve and I cleaned filter bed #3

Monday, December 21, 2015:

- * Received "Late" notice from DigSafelyNY for project on East Shore Rd. Was the first notification I had received for this project. Contacted Donna Shave to sort out the issue. Left telephone message for Gayle
- * Sewer installation beginning at Benzay & Harrison. No notification to DigSafelyNY was made.

Wednesday, December 23, 2015:

- * Responded to DigSafelyNY request for updated file information regarding Village office hours.

Tuesday, December 29, 2015:

- * Responded to DigSafelyNY mark out request for Benzay & Harrison. Responded with DO NOT DIG, until plan details are reviewed by the Village.

THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED. COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF CIVIL RIGHTS. ROOM 326W, WHITTEN BUILDING, 14TH & INDEPENDENCE AVE., SW, WASHINGTON, D.C. 202500410 (518) 895-2100 TDD# 1-800-662-1220

