

Jeffrey A. Iveson  
Water Commissioner, Village of Delanson  
1797 Main Street, P.O. Box 235  
Delanson, New York 12053

---

**Period of November 1, 2015 – November 30, 2015**

Total Amount of Water Used per Period:	1,004,000 gals.
Average Amount of Water Used per Day:	33,000 gals.
Total Amount of Hypochlorite Used per Period:	31 gals.
Average Amount of Hypochlorite Used per Day:	1.03 gals.

Monday, November 2, 2015:

- \* Received IOC/VOC results
- \* Attended Village Board meeting

Wednesday, November 4, 2015:

- \* Located valves on Thousand Acre Rd. and Railroad Ave.
- \* Telephone call to Gayle

Friday, November 13, 2015:

- \* Respond to mark out request at 996 Main Street and at the Cole Road crossing

Saturday, November 14, 2015:

- \* Steve and I flushed hydrants. Problem on West Shore Rd. Josh not available to accompany us.

Monday, November 16, 2015:

- \* Looked for leak. Conversations with Aanen, Chris Crowley and Gayle

Tuesday, November 17, 2015:

- \* Sent TTHM & HAA5 quarterly sample and monthly bacti sample to lab
- \* Numerous discussions with Aanen about RPZ function and repair

Wednesday, November 25, 2015:

- \* Steve and I cleaned filter bed #2

Monday, November 30, 2015:

- \* Mark out at Post Office for paving

---

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED BY FEDERAL LAW. COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF CIVIL RIGHTS, ROOM 326W, WHITTEN BLDG., 14<sup>TH</sup> & INDEPENDENCE AVE., SW, WASHINGTON. D.C. 202500410 (518)895-2199 TDD#11-800-662-1220**

