

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main St PO Box 235
Delanson, New York 12053

Period of June 1, 2016 – June 30, 2016

Total Amount of Water Used per Period:	1,169,000 gals.
Average Amount of Water Used per Day:	39,000 gals.
Total Amount of Hypochlorite Used per Period:	48.5 gals.
Average Amount of Hypochlorite Used per Day:	1.61 gals.

Wednesday, June 1, 2016:

- * Quarterly TTHM & HAA5 results: TTHM=52.4 (Avg.=70.5 MCL=80)
HAA5=48 (Avg.=55 MCL=60)

Tuesday, June 7, 2016:

- * Sent monthly operational reports to Schenectady Co. DOH

Wednesday, June 8, 2016:

- * Draining down filter bed #2

Thursday, June 9, 2016:

- * Steve and I cleaned filter bed #2
- * Contacted Crisafulli, Dale Warner, Joe Coppolo and Grimm Building Supply about ongoing Water Dept. matters

Monday, June 13, 2016:

- * Attended Village Board meeting

Tuesday, June 28, 2016:

- * Completed DigSafely mark out request for Main St. railroad crossing

THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED BY FEDERAL LAW. COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14TH AND INDEPENDENCE AVE. SW, WASHINGTON, D.C. 202500410 (518) 895-2100 TDD# 1-800-662-1220