

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main St. PO Box 235
Delanson, New York 12053

Period of May 1, 2016 – May 31, 2016

Total Amount of Water Used per Period:	1,080,000 gals.
Average Amount of Water Used per Day:	35,000 gals.
Total Amount of Hypochlorite Used per Period:	29.75 gals.
Average Amount of Hypochlorite Used per Day:	.95 gals.

Wednesday, May 4, 2016:

* Respond to DigSafelyNY mark out request on Mudge Rd

Monday, May 9, 2016:

* Attended Village Board meeting

Wednesday, May 11, 2016:

* Forwarded e-mailed water billing question from resident to Isabelle

Friday, May 13, 2016:

* Respond to DigSafelyNY mark out request on Rte. 20

Wednesday, May 18, 2016:

* Draining down filter bed #1

Thursday, May 19, 2016:

* Steve and I cleaned filter bed #1

Saturday, May 21, 2016:

* Steve and I flushed hydrants

Monday, May 23, 2016:

* Sent monthly bacti and quarterly TTHM & HAA5 samples to JH Consulting

Wednesday, May 25, 2016:

* Responded to DigSafelyNY mark out request on Duanesburg Churches Rd.

THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED BY FEDERAL LAW. COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF CIVIL RIGHTS, ROOM 326, WHITTEN BUILDING, 14TH & INDEPENDENCE AVE. SW, WASHINGTON, D.C. 202500410 (518)895-2100 TDD#1-800-662-1220

