

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main Street, PO Box 235
Delanson, New York 12053

Period of November 1, 2016 – November 30, 2016

Total Amount of Water Used per Period: 934,000 gals.
Average Amount of Water Used per Day: 31,000 gals.
Total Amount of Hypochlorite Used per Period: 31.5 gals.
Average Amount of Hypochlorite Used per Day: 1.05 gals.

Tuesday, November 2, 2016:

* Sent monthly operational reports to Schenectady Co. DOH

Monday, November 7, 2016:

* Attended Village Board meeting. Board okayed painting of doors and purchase of new hoist at plant.

Thursday, November 10, 2016:

* Several calls from residents related to discolored water

Friday, November 11, 2016:

* Call to Jack Frame regarding house fire within the village

Monday, November 14, 2016:

* Draining filter bed #1

Tuesday, November 15, 2016:

* Clearwells dropping

Wednesday, November 16, 2016:

* Steve and I cleaned filter bed #1

Tuesday, November 22, 2016:

* Draining filter bed #2

Thursday, November 24, 2016:

* Steve and I cleaned filter bed #2

Friday, November 25, 2016:

- * Steve noticed that chlorine levels in the distribution system were high. He called me, and we immediately took measures to remediate the problem. Spoke with Schenectady Co. DOH, Slack Chemical, and advised Mayor .

Monday, November 28, 2016:

- * Sent monthly bacti sample to JH Consulting

Wednesday, November 30, 2016:

- * Met with USDA representative at the plant. Discussion of water related issues

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED.
COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF
CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14TH & INDEPENDENCE AVE., SW,
WASHINGTON, D.C. 202500410 (518) 895-2199 TDD# 1-800-662-1220**