

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main Street PO Box 235
Delanson, New York 12053

Period of December 1, 2016 – December 31, 2016

Total Amount of Water Used per Period:	955,000 gals.
Average Amount of Water Used per Day:	31,000 gals.
Total Amount of Hypochlorite Used per Period:	32.7 gals.
Average Amount of Hypochlorite Used per Day:	1.05 gals.

Saturday, December 3, 2016:

- * Steve and I flushed hydrants
- * Replaced ballast in plant pipe gallery (basement) and 2 bulbs on main floor

Monday, December 5, 2016:

- * Sent quarterly TTHM and HAA5 samples to JH Consulting

Tuesday, December 6, 2016:

- * Sent monthly operational reports to Schenectady Co. DOH
- * Ordered DPD1A & 1B

Thursday, December 8, 2016:

- * Sent monthly report to Village Board to Isabelle

Monday, December 12, 2016:

- * Met Slack Chemical rep and switched out chlorine carboys

Tuesday, December 13, 2016:

- * Draining filter bed #3

Wednesday, December 14, 2016:

- * Sent monthly bacti sample to JH Consulting

Thursday, December 15, 2016:

- * Steve and I cleaned filter bed #3
 - * Sent required nitrate sample to JH Consulting
-

Tuesday, December 27, 2016:

* Changed UV bulbs

Thursday, December 29, 2016:

* Confirmed availability for Jan. meeting with Apt. complex developer

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED BY
FEDERAL LAW. COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA
DIRECTOR, OFFICE OF CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14TH &
INDEPENDENCE AVE SW, WASHINGTON, D.C. 202500410 (518)895-2199 TDD#1-800-
662-1220**