

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main St., PO Box 235
Delanson, New York 12053

Period of February 1, 2017 – February 28, 2017

Total Amount of Water Used per Period: 930,000 gals.
Average Amount of Water Used per Day: 33,000 gals.
Total Amount of Hypochlorite Used per Period: 21.5 gals.
Average Amount of Hypochlorite Used per Day: .76 gals.

Wednesday, February 8, 2017:

- * Steve and I cleaned filter bed #1

Thursday, February 9, 2017:

- * Emailed monthly report to Board to Isabelle
- * Sent monthly operational reports to Schenectady Co. DOH

Saturday, February, 11, 2017:

- * Steve and I flushed hydrants

Monday, February, 13, 2017:

- * Sent monthly bacti and quarterly TTHM & HAA5 samples to lab

Tuesday, February 14, 2017:

- * Responded to DigSafely mark out request on Alexander Rd.
- * Steve and I completed Water Department inventory at plant

Thursday, February 16, 2017:

- * Emailed 2016-2017 Budget estimates to Gayle
- * Emailed Water Dept. inventory to Isabelle

Monday, February 27, 2017:

- * Spoke with Debbie Dames about her complaint of low water pressure
- * Attended Budget Workshop

Tuesday, February 28, 2017:

- * TTHM sample results Quarterly: 65.0 4 Quarter Avg.: 84.325
- * HAA5 sample results Quarterly: 58 4 Quarter Avg.: 66.25

THIS IS AN EQUAL OPPORTUNITY PROGRAM.. DISCRIMINATION IS PROHIBITED BY LAW. COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14TH & INDEPENDENCE AVE., SW, WASHINGTON, D.C. 202500410 TDD#1-800-662-1220 (518)95-2199