

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main St., PO Box 235
Delanson, New York 12053

Period of March 1, 2017 – March 31, 2017

Total Amount of Water Used per Period:	966,000 gals.
Average Amount of Water Used per Day:	31,000 gals.
Total Amount of Hypochlorite Used per Period:	57.79 gals.
Average Amount of Hypochlorite Used per Day:	1.86 gals.

Wednesday, March 8, 2017:

- * Sent monthly operational reports to Schenectady Co. DOH

Thursday, March 9, 2017:

- * Emailed monthly report to Board to Isabelle

Friday, March 17, 2017:

- * Spoke with Kevin McCarthy about low pressure at his home

Tuesday, March 21, 2017:

- * Made arrangements for Annual Sanitary Survey with Dominic DiCarlo

Wednesday, March 22, 2017:

- * Sent monthly bacti sample to JH Consulting

Tuesday, March 28, 2017:

- * Draining filter bed #2
- * Met Dominic Di Carlo for Annual Sanitary Survey at the plant

Wednesday, March 29, 2017:

- * Steve and I cleaned filter bed @2
- * Steve and I attended training course in Utica, New York

Friday, March 31, 2017:

- * Responded to DigSafely emergency markout on Thousand Acre Rd. related to pole replacement

THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED BY FEDERAL LAW. COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14TH & INDEPENDENCE AVE. SW, WASHINGTON, D.C. 202500410 (518)895-2199 TDD#1-800-662=1220