

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main St., PO Box 235
Delanson, New York 12053

Period of May 1, 2017 – May 31, 2017

Total Amount of Water Used per Period:	991,000 gals.
Average Amount of Water Used per Day:	32,000 gals.
Total Amount of Hypochlorite Used per Period:	39.25 gals.
Average Amount of Hypochlorite Used per Day:	1.26 gals.

Thursday, May 4, 2017:

* Emailed report to Village Board to Isabelle

Friday, May 5, 2017:

* DigSafely mark out at 696 Main Street for foundation repair work

Monday, May 8, 2017:

* Attended Village Board meeting

Saturday, May 13, 2017:

* Steve and I flushed hydrants

Monday, May 15, 2017:

* Sent monthly bacti and quarterly TTHM & HAA5 samples to lab

Thursday, May 18, 2017:

* Responded to mark out requests at 664 Alexander Rd. (driveway installation), 545 Mudge Rd. (cross culvert replacement), and 680-699 Mudge Rd. (cross culvert replacement)

Friday, May 26, 2017:

* Quarterly TTHM & HAA5 sample results:
TTHM=95.5 (Quarterly Avg.= 95.1) HAA5= 85.6 (Quarterly Avg.=75.6)

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED.
COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR. OFFICE OF
CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14th & INDEPENDENCE AVE, SW,
WASHINGTON, D.C. 202500410 (518)895-2116 TDD#1-800-662-1220**

