# Jeffrey A. Iveson Water Commissioner, Village of Delanson 1797 Main St., PO Box 235 Delanson, New York 12053

### Period of June 1, 2017 - June 30, 2017

Total Amount of Water Used per Period:

Average Amount of Water Used per Day:

Total Amount of Hypochlorite Used per Period:

Average Amount of Hypochlorite Used per Day:

1.33 gals.

# Wednesday, June 7, 2017:

- \* Water main break on Main St.
- \* Conversation with DOH. No need for BOIL WATER notice
- \* Flushed hydrants on East Shore Road & Main St.
- \* (.26 chlorine residual)
- \* Sent monthly operational reports to Schenectady Co. DOH

### Thursday, June 8, 2017:

\* Emailed monthly report to Village Board to Isabelle

#### Monday, June 12, 2017:

\* Attended Village Board meeting

#### Wednesday, June 14, 2017:

\* Responded to two DigSafely mark out requests on Mudge Rd. for culvert replacements

#### Wednesday, June 21, 2017:

- \* Sent monthly bacti report to JH Consulting
- \* Responded to DigSafely mark out request on Alexander Rd.

# Friday, June 23, 2017:

\* Rick Corneer called me to ask that the water shut off be relocated to facilitate building clean-up at his property at his Main St. property. I told him that it could not be moved, and that he should take care not to damage it. I also informed him that there is a service line in the basement, and that he should not damage it.

Saturday, June 24, 2017:

\* Lowered the shut off at Corneer property on Main St., and protected it with a saw horse. Informed Mayor of protective measures taken, and asked that she take pictures to document the conditions.

Monday, June 26, 2017:

\* Responded to DigSafely mark out request on Mudge Rd.

NOTE: Omitted from May 2017 water report. Shut off at Herb Winnie residence (203 Stewart Drive) was replaced during May 13th hydrant flushing.

THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED. COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14<sup>TH</sup> & INDEPENDENCE AVE., SW, WASHINGTON, D.C. 202500410 (518)895-2100) TDD# 1-800-662-1220