

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main St. PO Box 235
Delanson, New York 12053

Period of August 1, 2017 – August 31, 2017

Total Amount of Water Used per Period:	1,065,000 gals,
Average Amount of Water Used per Day:	34.000 gals.
Total Amount of Hypochlorite Used per Period:	53.75 gals.
Average Amount of Hypochlorite Used per Day:	1.75 gals.

Wednesday, August 2, 2017

- * Telephone call from Gayle. DCS permit had been finalized and paid for. Water needed to be turned off ASAP. shut water off at street. Valve turned very hard. Called Mike Walpole to report that the bleeder pipe near the hydrant had been ripped out. Mike not aware of damage. Said he would look into it and call me back tomorrow.
- * Steve and I cleaned filter bed #1

Tuesday, August 8, 2017

- * Sent monthly operational reports to County DOH

Wednesday, August 9, 2017

- * Text from Gayle. Village Board meeting postponed until Monday, August 21st
- * Responded to three mark out requests: Mudge/Skyline/Duanesburg Churches Rd. for pole and anchor installation, Rte, 395 for guard rail repair, and 403 East Shore Rd. for stump removal)
- * Steve and I cleaned filter bed #2

Thursday, August 10, 2017

- * Received email from Mike Walpole with electronic copies of pressure testing reports, bacti sample reports, and photos of existing piping at the DCS project

Saturday, August 12, 2017

- * Steve and I flushed hydrants

Tuesday, August 15, 2017

- * Sent monthly bacti and quarterly TTHM & HAA5 samples to JH Consulting

Wednesday, August 16, 2017

- * Responded to an email from Signature Home Buyers regarding a water meter reading on Quaker Lane

Tuesday, August 22, 2017

- * Responded to mark out request at 610 Main St. (Seals) for installation of underground electrical service

Wednesday, August 30, 2017:

- * Responded to mark out request at 1929 Main Street

Thursday, August 31, 2017:

- * Draining filter bed #3
- * Text exchange with Gayle regarding complaint of low pressure/no water from Lynn O'Rourke. Phone conversation with Lynn. Water problem resolved. Text to Gayle at 9PM to advise her..

THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED BY FEDERAL LAW. COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14TH & INDEPENDENCE AVE. SW, WASHINGTON D.C. 202500410 (518)895-2199 TDD# 1-800-662-1220

