

Jeffrey A. Iveson  
Water Commissioner, Village of Delanson  
1797 Main St. PO Box 235  
Delanson, New York 12053

---

**Period of July 1, 2017 – July 31, 2017**

Total Amount of Water Used per Period:	894,000 gals.
Average Amount of Water Used per Day:	29,000 gals.
Total Amount of Hypochlorite Used per Period:	54,000 gals.
Average Amount of Hypochlorite Used per Day:	1.74 gals.

Thursday, July 6, 2017

- \* Emailed monthly report to Village Board to Isabelle

Friday, July 7, 2017

- \* Sent monthly operational reports to County DOH

Thursday, July 13, 2017

- \* Telephone call from Aanen concerning waterline modifications at DCS. Contractor hit  $\frac{3}{4}$ " copper service line that fed the former Almond House
- \* Telephone call to Gayle. Discussion of my concerns with school project (no plan submitted to Village, licensed inspector on crew?) Gayle confident that the crew "Will do a good job".
- \* Telephone call to Dominic Di Carlo . He will check with NYSDOH about my concerns
- \* Sent text to Jack Frame

Friday, July 14, 2017

- \* No response from Jack Frame
- \* Responded to mark out request at 1929 Main St. (fence installation) and Elementary school
- \* Forwarded email concerning water billing to Isabelle

Monday, July 17, 2017

- \* Attended Village Board meeting. Josh will contact DCS project manager to set up meeting to discuss villages' concerns.

Wednesday, July 19, 2017

- \* Responded to mark out requests at DCS (waterline) and Alexander Rd. (solar farm)

Friday, July 21, 2017

- \* Contractor at DCS hit water main. Maps showed the main was 4" cast iron, but it was actually 2" copper. I responded and turned water off.
- \* Inquired when meeting had been scheduled with village and school officials. Was told no meeting had been set up.

Tuesday, July 25, 2017

- \* Forwarded email request for water billing to Isabelle
- \* Sent monthly bacti sample to JH Consulting
- \* Was copied on email concerning scheduling of meeting with DCS officials

Wednesday, July 26, 2017

- \* Meeting with school officials and Village Board members to discuss project progress, and permitting requirements. Contractor will supply copies of certifications, plans and lab results to me.

