

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main St., PO Box 235
Delanson, New York 12053

Period of April 1, 2018 – April 30, 2018

Total Amount of Water Used per Period:	1,042,000 gals.
Average Amount of Water Used per Day:	35,000 gals.
Total Amount of Hypochlorite Used per Period:	23.75 gals.
Average Amount of Hypochlorite Used per Day:	.79 gals.

Wednesday, April 4, 2018:

- * Received email from Mike Walpole regarding the status of items to be completed on DCS project

Thursday, April 5, 2018:

- * Contacted Joe Coppola regarding finished water turbidity meter and chart recorder paper
- * Sent monthly operational reports to Schenectady Co. DOH

Monday, April 9, 2018:

- * Attended Village Board meeting
- * Received call from Scot Tetrault regarding shutting off his water
- * Email from Mike Walpole about DCS project

Tuesday, April 10, 2018:

- * Located shut off at Scot Tetrault's

Wednesday, April 11, 2018:

- * Checked valve at Scot Tetrault's to verify that it was operational
- * Called Jack Halstuch concerning the status of the AWQR
- * Called Scot Tetrault to schedule time for his water to be shut off
- * Received text from Gayle that a sub-contractor on the DCS project was drawing water from the hydrant

Thursday, April 12, 2018:

- * Shut off water at Scot Tetrault's after work
- * Then met with Mike Walpole at DCS to inspect water main capping. (Gayle will notify residents in the area to expect interruptions in service)

Friday, April 13, 2018{

- * Forwarded email to Isabelle regarding questions from new owner of 299 Thousand Acre Rd to Isabelle
- * Responded to mark out request for Scotch ridge Rd for hidden pet fence

Monday, April 16, 2018:

- * Steve and I cleaned filter bed #2

Wednesday, April 18, 2018:

- * Met Joe Coppolo at the plant. He conducted circuit tests and replaced bulb on finished water turbidity meter and it is operational. He also supplied us with three boxes of chart recorder disks.

Thursday, April 19, 2018:

- * Steve and I cleaned filter bed #1

Tuesday, April 24, 2018:

- * Sent monthly bacti sample to JH Consulting

Wednesday, April 25, 2018:

- * Steve and I attended a class toward license recertification
- * Message from Gayle that she had had complaints of low water pressure from Lynn O'Rourke and the Ryders. Went to Ryders, and they said their pressure was fine. Went to O'Rourke's and discussed potential issues within her home that might contribute to low pressure issues with her plumber