

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main St PO Box 235
Delanson, New York 12053

Period of December 1, 2018 – December 31, 2018

Total Amount of Water Used per Period:	910,000 gals.
Average Amount of Water Used per Day:	29.000 gals.
Total Amount of Hypochlorite Used per Period:	45.5 gals:
Average Amount of Hypochlorite Used per Day:	1.46 gals.

Wednesday, December 5, 2018

- * Email from Marcia Galka, with a list of required samples for 2018. There was confusion over which samples had been taken by DOH Called Co. and got it straightened out.

Thursday, December 6, 2018:

- * Sent monthly bacti sample to JH Consulting
- * email report to Isabelle

Monday, December 24, 2018:

- * Changed UV bulbs at plant

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED.
COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF
CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14TH & INDEPENDENCE AVE. SW,
WASHINGTON DC 202500419 (518)895-2100 TDD# 1-800-662-1220**