

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main St. PO Box 235
Delanson, New York 12053

Period of November 1, 2018 – November 30, 2018

Total Amount of Water Used per Period:	866,000 gals.
Average Amount of Water Used per Day:	29,000 gals.
Total Amount of Hypochlorite Used per Period:	36 gals.
Average Amount of Hypochlorite Per Day:	1.2 gals.

Thursday, November 1, 2018:

- * Spoke with owner of 111 Rose St. regarding water service
- * Draining filter bed #1
- * Emailed report to Board to Isabelle

Friday, November 2, 2018:

- * Mark out request at 331 Thousand Acre Rd. (Angela Elman) for foundation

Monday, November 5, 2018:

- * Sent monthly operational reports to Schenectady DOH
- * Steve and I cleaned filter bed #1
- * Attended Village Board meeting

Tuesday, November 6, 2018:

- * Completed mark out at 331 Thousand Acre Rd.

Wednesday, November 7, 2018:

- * Put up signs for hydrant flushing
- * Responded to mark out request at 1200 Alexander Rd. for stump removal

Saturday, November 10, 2018:

- * Steve and I flushed hydrants

Tuesday, November 13, 2018:

- * Sent monthly bacti sample and quarterly TTHM & HAA5 samples to JH Consulting
- * Email from Jack Halstuch regarding annual sampling requirements. He asked which samples NYSDOH provided for the village this year. Called Dominick. He stated that the County had sampled for IOC, POC, SOC on May 22nd. I emailed Jack Halstuch with that info

Wednesday, November 28, 2018:

- * Call from Isabelle in reference to turning on the water on for Elm St. resident. Contacted resident. She told me that they were not ready for the water to be turned on. Checked with Isabelle. She said that it must have been an old message.

Thursday, November 29, 2018:

- * Rudy Benzay stopped in at the garage to ask about the mark out for his gate relocation project at Ionic Labs. Told him that I had already completed it. Rudy asked why it hadn't been marked from the shut off to his building. I told him that the village was responsible to mark only to the shut off, and that his contractor would need to mark the line on his private property.

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED.
COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF
CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14TH & INDEPENDENCE AVE.
SW, WASHINGTON, D.C. 202500410 (518)8 895-2100 TDD# 1-800-662-1220**