

Jeffrey A. Iveson  
Water Commissioner, Village of Delanson  
1797 Main St. PO Box 235  
Delanson, New York 12053

---

**Period of February 1, 2019 – February 28, 2019**

Total Amount of Water Used per Period:	900,000 gals.
Average Amount of Water Used per Day:	32,000 gals.
Total Amount of Hypochlorite Used per Period:	20.25 gals.
Average Amount of Hypochlorite Used per Day:	.72 gals.

Wednesday, February 6, 2019:

- \* Sent monthly operational reports to Schenectady Co. DOH

Thursday, February 7, 2019:

- \* Put up Hydrant Flushing signs
- \* Emailed monthly report to the Village Board to Isabelle

Saturday, February, 9, 2019:

- \* Steve & I flushed hydrants

Monday, February 11, 2019:

- \* Sent quarterly TTHM & HAA5 samples and monthly bacti sample to JH Consultants

Wednesday, February 20, 2019:

- \* Received email notification that USA Bluebook order had shipped
- \* TTHM quarterly sample = 53.1  
4 quarter avg. = 73.8 MCL=80
- \* HAA5 quarterly sample = 57  
4 quarter avg. = 77.25 MCL = 60

Thursday, February 21, 2019:

- \* Picked up DPD 1A & 1B
- \* Draining down filter bed #2

Wednesday, February 27, 2019:

- \* Steve and I cleaned filter bed #2

---

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED.  
COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF  
CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14<sup>TH</sup> & INDEPENDENCE AVE SW,  
WASHINGTON, D.C. 202500410 (518) 895-2100 TDD# 1-800-662-1220**