

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main St., Box 235
Delanson, New York 12053

Period of April, 2019 – April 30, 2019

Total Amount of Water Used per Period:	1,076,000 gals.
Average Amount of Water Used per Day;	36,000 gals.
Total Amount of Hypochlorite Used per Period:	20.75 gals.
Average Amount of Hypochlorite Used per Day:	.69 gals.

Wednesday, April 3, 2019:

* Sent monthly operational reports to Co. DOH

Thursday, April 3, 2019:

* Emailed report to Village Board to Isabelle

Monday, April 8, 2019:

* Attended Village Board meeting

Wednesday, April 10, 2019:

* Sent monthly bacti sample to JH Consulting

Monday, April 15, 2019:

* Returned telephone call from Amanda Gorman

Thursday, April 25, 2019:

* Respond to DigSafely mark out request at 716 Duanesburg Churches Rd for a water well drilling

Monday, April 29, 2019:

* Called Jack Halstuch concerning AWQR. He said it was returned to the village several weeks ago. Spoke with Gayle about the AWQR and signing the Oath of Office book at May meeting.

Tuesday, April 30, 2018:

* Received message from DigSafely for a mark out at YMCA for basketball court

THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED. CO,PLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14TH & INDEPENDENCE AVE., SW. WASHINGTON, D.C. 202500410 (518) 895-2100 TDD# 1-800-662-1220