

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main St. P.O. Box 235
Delanson, New York 12953

Period of December 1, 2019 - December 31, 2019

Total Amount of Water Used per Period:	900,000 gals.
Average Amount of Water Used per Day:	29,000 dals.
Total Amount of Hypochlorite Used per Period:	29.25 gals.
Average Amount of Hypochlorite Used per Day:	.94 gals.

Tuesday, December 3, 2019:

* Copied in Jason Preisner's email to Co. DOH

Wednesday, December 4, 2019:

* Received info on Carus 8600 from Travis at Slack Chemical

Thursday, December 5, 2019:

* Mark out on Alexander Rd. for National Grid pole replacement

* Emailed monthly report to Board to village office

Wednesday, December 11, 2019:

* Sent monthly bacti sample to JH Consulting\ * Responded to another mark out request in Alexander Rd. for pole replacement

Thursday, December 12, 2019:

* TTHM: Quarterly sample=80.4 4 quarter average=70.72

HAA5: Quarterly sample=69.8 4 quarter average=56.11

Monday, December 16, 2019:

* Received and responded to mark out on Rte 20 for a fuel spill

Wednesday, December 18, 2019:

* Replaced UV bulbs at plant

Thursday, December 19, 2019:

* Forwarded Tri State Wastewater invoice to Nicole

**TGIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED.
COMPLAINYS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF
CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14TH & INDEPENDENCE AVE. SW,
WASHINGTON, D.C. 202500410 (518)895-2100 TDD# 1-800-662-1220**

