

Jeffrey A. Iveson  
Water Commissioner, Village of Delanson  
1797 Main St. Box 235  
Delanson, New York 12053

---

**Period of January 1, 2020 – January 31, 2020**

Total Amount of Water Used per Period:	1,027,000 gals.
Average Amount of Water Used per Day:	33,000 gals.
Total Amount of Hypochlorite Used per Period:	27.25 gals.
Average Amount of Hypochlorite Used per Day:	.87 gals.

Thursday, January 2, 2020:

- \* Steve and I cleaned filter bed #3

Friday, January 3, 2020:

- \* Forwarded information regarding Carus 8600 to Dominick Di Carlo
- \* Received AWQR form from JH Consulting

Monday, January 6, 2020:

- \* Responded to Dominick's questions relating to Carus 8600

Tuesday, January 7, 2020:

- \* Water main break detected in front of 1929 Main St.
- \* Sent monthly operational reports to Schenectady Co.

Wednesday, January 8, 2020:

- \* Responded to mark out on Main St related to water main break
- \* Carver Construction repaired water main break
- \* Monthly bacti sample sent to JH Consulting

Thursday, January 9, 2020:

- \* Sent monthly report to Board to Nicole

Monday, January 13, 2020:

- \* Attended Village Board meeting
- \* Collected remaining cones at site of water main break

Wednesday, January 15, 2020:

- \* Sent information concerning water system, requested by Jason Preisner to Lamont Engineers

Wednesday, January 22, 2020:

\* Ordered chemicals for the plant

Friday, January 31, 2020:

\* Responded to three mark out requests:

200 Delevan Rd for installation of a water well

909 Alexander Rd for installation of a driveway

Rte 20 between Mudge Rd. & Rte 395 for soil borings

---

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED.  
COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF  
CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14<sup>TH</sup> & INDEPENDENCE AVE. SW,  
WASHINGTON, D.C. 202500410 (518)895-2100 TDD#1-800-662-1220**