

Jeffrey A, Iveson  
Water Commissioner, Village of Delanson  
1797 Main St. PO Box 235  
Delanson, New York 12053

---

**Period of November 1, 2019 – November 30, 2019**

Total Amount of Water Used per Period:	1,014,000 gals.
Average Amount of Water Used per Day:	34,000 gals.
Total Amount of Hypochlorite Used per Period:	36 gals.
Average Amount of Hypochlorite Used per Day	1.29 gals.

Monday, November 4, 2019:

- \* Attended Village Board meeting

Saturday, November 9, 2019:

- \* Steve and I cleaned filter bed #1

Tuesday, November 12, 2019:

- \* Molly let me know that the UV bulbs had been delivered

Wednesday, November 13, 2019

- \* Draining filter bed #2
- \* Put hydrant flushing signs out
- \* Responded to mark out request on Rte. 395 for guard rail repair
- \* Checking wiring in bulb sockets at filtration plant

Wednesday, November 13, 2019:

- \* Slack Chemical put labels on plant walls for placement of chemicals

Thursday, November 14, 2019:

- \* Steve and I cleaned filter bed #2

Saturday, November 16, 2019:

- \* Steve and I flushed hydrants

Monday, November 18, 2019:

- \* Sent monthly bacti, and quarterly TTHM and HAA5 samples to lab

Tuesday, November 19, 2019:

- \* Received/Responded to mark out on Rte. 395 for guard rail repair

---

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED.  
COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF  
CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14<sup>TH</sup> & INDEPENDENCE  
AVE.SW, WASHINGTON DC 202500410 (518)895-2100 TDD#1-800-662-1220**