

Jeffrey A. Iveson  
Water Commissioner, Village of Delanson  
1797 Main St. P.O. Box 235  
Delanson, New York 12053

**Period of March 1, 2020 – March 31, 2020**

---

Total Amount of Water Used per Period:	924,000 gals.
Average Amount of Water Used per Day:	30,000 gals.
Total Amount of Hypochlorite Used per Period:	20.75 gals.
Average Amount of Hypochlorite Used per Day	.66 gals.

Wednesday, March 4, 2020:

- \* Jason sent copy of SEQR review forms

Thursday, March 5, 2020:

- \* Emailed copy of 2019 fourth quarter TTHM & HAA5 results to Jason
- \* Emailed monthly report to Board to Nicole

Friday, March 6, 2020:

- \* Completed AWQR and mailed to Jack Halstuch
- \* Verified Nicole's list of properties with no water service
- \* Emailed hydrant flushing dates to Nicole
- \* Updated Water Dept. inventory

Monday, March 9, 2020:

- \* Attended Village Board meeting. Discussion of YWCA pool filling

Wednesday, March 11, 2020:

- \* Steve and I attended a course in Troy. Received credits toward recertification
- \* Added pricing estimates to Water Department Inventory and forwarded to Nicole

Tuesday, March 17, 2020:

- \* Annual Sanitary Survey cancelled due to the volume of telephone calls being received at DOH concerning COVID-19

Wednesday, March 18, 2020:

- \* Sent monthly bacti sample to JH Consulting

Friday, March 20, 2020:

- \* Responded to DigSafely mark out request at 2029 Main St. (Verizon)

Tuesday, March 31, 2020:

- \* Steve and I cleaned filter #2

\* Noticed that water usage had spiked on Monday, March 30<sup>th</sup>.  
(approx.. 14,000 gals. more than usual) Called Dante at the Y, he said  
that they had been closed, and hadn't used any water)

---

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED,  
COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF  
CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14<sup>TH</sup> & INDEPENDENCE AVE. SW,  
WASHINGTON, D.C. 202500410 TDD# 1-800-662-1220 (518) 895-2100**