

Jeffrey A, Iveson
Water Commissioner, Village of Delanson
1797 Main St. PO Box 235
Delanson, New York 12053

Period of August 1, 2020 – August 31, 2020

Total Amount of Water Used per Period: 1,038,000 gals.
Average Amount of Water Used per Day: 33,000 gals.
Total Amount of Hypochlorite per Period: 50 gals.
Average Amount of Hypochlorite Used per Day: 1.61 gals.

Saturday, August 1, 2020:

- * Steve and I cleaned filter bed #3

Thursday, August 6, 2020:

- * Sent monthly report to Board to Nicole

Saturday, August 8, 2020:

- * Steve and I flushed hydrants

Monday, August 10, 2020:

- * Participated in Village Board via Zoom
- * Sent monthly bacti and quarterly TTHM and HAA5 samples to lab

Tuesday, August 11, 2020:

- * Responded to DigSafely mark out request for 1521 Alexander Rd. for National Grid pole replacement
- * Forwarded letter from Dominick DiCarlo (DOH) concerning re-certification extension
- * Spoke with salesman from Surpass Chemical regarding pricing and delivery to the plant

Thursday, August 13, 2020:

- * Attempted to register for new DigSafely Exactix program. No Luck. Spoke with office and got it straightened out.

Monday, August 31, 2020:

- * TTHM quarterly sample: 98.9 4 quarter avg.: 73.125
HAA5 quarterly sample: 24.1 4 quarter avg.: 56.2

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED.
COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF
CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDINGM 14TH & INDEPENDENCE AVE SW,
WASHINGTON, D.C., 202500410 (518) 895-2100 TDD#1-800-662-1220**