

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main St. PO Box 235
Delanson, New York 12053

Period of November 1, 2020 – November 30, 2020

Total Amount of Water Used per Period:	973,000 gals
Average Amount of Water Used per Day	32,000 gals.
Total Amount of Hypochlorite Used per Period:	42.5 gals.
Average Amount of Hypochlorite Used per Day:	1.08 gals.

Monday, November 2, 2020:

- * Attended Village Board meeting via Zoom

Tuesday, November 3, 2020:

- * At Mayors request, postponed plant tour with she and Bucky

Wednesday, November 4, 2020:

- * Purchased electric light fixtures for the plant at Allied

Thursday, November 5, 2020:

- * Replaced light fixture near door at plant
- * Spoke with Travis at Slack Chemical about Carus Poly Ortho
- * Spoke with Slack's lab in Illinois about lab certification
- * Spoke with Dominick Di Carlo at Schenectady Co. DOH about replacing Carus 3190 with Carus Poly Ortho
- * Confirmed my telephone conversation with Dominick through an email to both he and Jennifer Priebe Forwarded info to Gayle

Wednesday, November 11, 2020:

- * Called JH Consulting to request TTHM & HAA5 sample kit
- * Heard from Jason Preisner that it was OK to turn on #2 & #3

Thursday, November 12, 2020:

- * Hazard Mitigation Plan update meeting cancelled

Saturday, November 14, 2020:

- * Steve and I flushed hydrants
- * Made arrangement with residents to collect Lead/Copper samples

Monday, November 16, 2020:

- * Picked up Lead/Copper samples from residents
- * Sent monthly bacti and quarterly TTHM & HAA5 samples to lab
- * Texted Jason concerning the return of the keys for the plant from Aztec

Wednesday, November 18, 2020:

* Text from Jason that he will follow through on key return

Tuesday, November 24, 2020:

- * Responded to question from Melanie Merrick regarding well water
- * Draining filter #3

Wednesday, November 25, 2020:

- * Steve and I cleaned filter #3

Monday, November 30, 2020:

- * Jason resolved issue with Aztec Construction concerning lead cords from the plant that were packed up by workers when the project ended

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED.
COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF
CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14TH & INDEPENDENCE AVE SW,
WASHINGTON, DC 202500410 (518)895-2100 TDD# 1-800-662-1220**