

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main St. P.O. Box 235
Delanson, New York 12053

Period of January 1, 2021 – January 31, 2021

Total Amount of Water Used per Period:	923,000 gals.
Average Amount of Water Used per Day:	30,000 gals.
Total Amount of Hypochlorite Used per Period:	28 gals.
Average Amount of Hypochlorite Used per Day:	.90 gals.

Monday, January 4, 2021:

- * Was advised by several residents of low water pressure within the Village around 9:30 AM
- * Carver contacted to repair the break (near firehouse)

Tuesday, January 5, 2021:

- * Changed lightbulbs in pipe gallery at plant. (Lower level. East end)
- * Replaced fixtures in chemical pump room

Wednesday, January 6, 2021:

- * Sent monthly bacti sample, PFOA/S and 1.4 Dioxane samples to lab
- * Sent monthly operational reports to County DOH
- * Aztec Construction at plant to repair link seals

Thursday, January 7, 2021:

- * Emailed report to Village Board to Nicole

Sunday, January 19, 2021:

- * Draining filter #1

Monday, January 11, 2021:

- * Attended Village Board meeting via Zoom
- * Jason Preisner sent Aztec invoice for payment
- * County sent an explanation of PFOA/S and 1.4 Dioxane MCL implementation

Wednesday, January 20, 2021:

- * Nicole forwarded the Carver bill from the break for my comment

Saturday, January 23, 2021:

- * Cleaned filter bed #1

Monday, January 25, 2021;

- * Email from Gayle asking if Steve or I wanted to be included in the County vaccination program. Texted her back.
- * Five mark out requests for Thousand Acre Rd. pole/anchor replacement /installation
- * Mark out request for 187 Railroad Ave for pole replacement
- * Forward email to Nicole concerning water billing question

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED.
COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF
CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING. 14TH & INDEPENDENCE AVE. SW,
WASHINGTON, D.C. 202500410 (518)895-2100 YDD# 1-800-662-1220**