

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main St. P.O. Box 235
Delanson, New York 12953

Period of June 1, 2021 – June 31, 2021

Total Amount of Water Used per Period: 1,065,000
Average Amount of Water Used per Day:35,000
Total Amount of Hypochlorite Used per Period:37.5 Gal
Average Amount of Hypochlorite Used per Day: 1.25*

Wednesday June 2

*Sent Monthly water reports to health dept

*Respond to RT 395 for mark out request for Dot culvert replacement

Thursday June 3

Respond to 395 for a mark out request. I called field contact on ticket left a message for them that filter fabric needed to be installed in ditch line to slow water down as the ditch was to the inlet pipe under Rt 395 direct feed to reservoir.

*Received message from J H they did not receive my thm/Ha5 samples ,I had sent them with my monthly sample?

*Also sent my PFOA/S 1.4 Dioxane samples in

Thursday June 10

*Water Main break 187 East Shore Rd Grygas res.,contacted Willam Larnard to repair the break /repaired

Monday June 14

*Larnard came back to finish the break clean up in the driveway

*Attend Village board meeting

*Received sample results for VOC"s

Wednesday June 16

*Sent in monthly water samples

*Noticed suspicious activity at (old) water building notified sheriff dept. met with them filed a report.

Thursday June 17

*Placed order for zinc with slack chemical

Thursday June 24

*received results from J H for SOC"s/Table 8bc results

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED..
COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF
CIVIL RIGHTS, ROOM 326W, WHITTEN BUI;DING, 14TH & INDEPENDENCE AVE. SW,
WASHINGTON, D.C. 202500410 (518) 895-2100 202500410 (518) 895-2100 TDD# 1-
800-662-1220**