

Jeffrey A. Iveson  
Water Commissioner, Village of Delanson  
1797 Main St. P.O. Box 235  
Delanson, New York 12953

---

**Period of December 1, 2021- December 31, 2021**

Total Amount of Water Used per Period: 1,063,000  
Average Amount of Water Used per Day: 34,000  
Total Amount of Hypochlorite Used per Period: Gal 31  
Average Amount of Hypochlorite Used per Day: Gal 1

Wednesday December 1<sup>st</sup>

- Received a second price quote for emergency repair to water plant office heater from Esperance LP and sent it to the Mayor and clerk.

Monday December 6<sup>th</sup>

- Received a new price increase quote from Jem Enterprise on chemical injection pump for potential upcoming pump replacement.

Saturday December 11<sup>th</sup>

- JH labs sent 4<sup>th</sup> quarter DPB's

Friday December 17<sup>th</sup>

- JH labs sent Iron & Manganese Corrosion Parameters
- JH labs sent lab results for PFOA/S & Dioxane

Tuesday December 21<sup>st</sup>

- JH lab sent Iron & Manganese results back for fourth quarter.

Wednesday December 22<sup>nd</sup>

- Sent lab results for raw and finished water to Slack chemical lab, to verify correct phosphate.

Sunday December 26<sup>th</sup>

- Work on UV Chamber, cleaning glass tubes and sealing of O-ring on paddle wiper.

Monday December 27<sup>th</sup>

- Replace UV bulbs in UV Chamber, checked duty sensor with reference sensor.
- Note: One bad lead on bulb 3 in chamber, trying to locate parts, manufacturer is no longer in business.

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED.. COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF CIVIL RIGHTS, ROOM 326W, WHITTEN BUI;DING, 14<sup>TH</sup> & INDEPENDENCE AVE. SW, WASHINGTON, D.C. 202500410 (518) 895-2100 202500410 (518) 895-2100 TDD# 1-800-662-1220**