

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main St. P.O. Box 235
Delanson, New York 12053

Period of January 1, 2022 – January 31, 2022

Total Amount of Water Used per Period:	1,176,000gals.
Average Amount of Water Used per Day:	38,000 gals.
Total Amount of Hypochlorite Used per Period:	25 gals.
Average Amount of Hypochlorite Used per Day:	.80 gals.

Sunday, January 2, 2022:

- Received email from Lamont Engineering, Regarding THM results for the EPA.

Tuesday, January 4, 2022:

- Received annual quality questioner from JH Consulting.

Thursday, January 6, 2022:

- Lamont sent fourth quarter sampling results to EPA (Updated)

Monday, January 10, 2022:

- EPA responded to Lamont, Village was copied in they received their fourth quarter results.

Tuesday, January 11, 2022:

- Digs safely mark out request for 187 East Shore Rd.

Tuesday, January 18, 2022:

- Sent in monthly Bac-T samples.

Wednesday, January 19, 2022:

- Cleaned filter bed #3

Thursday, January 20, 2022:

- JH sent back monthly Bac-T results.

Wednesday, January 26, 2022:

- Received numerous calls and emails regarding no water.
- Water break was found on Railroad Ave, worked to locate shut off valve and remove ice from valve box to shut down Railroad Ave.
- Notified residents and businesses of no water until approx. 12pm the following day.
- Notified health department of water main break, health department followed up with a boil water order effective immediately.
- Made called to carver construction to coordinate a repair of the break the following day.

Friday, January 28, 2022:

- Spoke with contractor, brake was repaired, flushed water main and chlorinated line on Railroad Ave.
- Took water samples for break to JH lab, to have Bac-T test done on Railroad Ave.

Saturday, January 29, 2022:

- Took water samples again on Railroad Ave, for Bac-T Test
- Received cloudy water complaint from 144 Rose Street. Went to residents to speak with homeowner.

Sunday, January 30, 2022:

- Received email from JH lab, Results from both days testing Railroad Ave came back negative, called the health department with results.
- Health Department called back with official notice to lift boil water order.

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED.
COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF
CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING. 14TH & INDEPENDENCE AVE. SW,
WASHINGTON, D.C. 202500410 (518)895-2100 YDD# 1-800-662-1220**