

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main St. P.O. Box 235
Delanson, New York 12953

Period of March 1, 2022 – March 31, 2022

Total Amount of Water Used per Period: 1,209,000
Average Amount of Water Used per Day: 39,000
Total Amount of Hypochlorite Used per Period: 41.25 Gal
Average Amount of Hypochlorite Used per Day: 1.33 Gal

Tuesday March 1st:

- Received a message from the Mayor, She requested that I take a look at Thousand Acre Rd, the Rd is sinking in break area.
- Looked at break area and there is 2 placed, I advised the mayor that need material due to settling.

Wednesday March 2nd:

- Received message from the clerk, water violation notices came from health department. Advised 1 violation was operators for failure to supply sodium sample. Spoke to lab in Latham, they failed to send sample in December when I called and asked if my sample schedule was complete.
- The other notices from health department were from THM and HA5 violations when levels were above the MCL and Filtration plant was unable to meet the current standards.

Saturday March 5th

- Flush hydrants
- Mark out request from dig safe on Rt 395 ,425 for construction on driveway ,new home.

Tuesday March 8th

- Dig safe mark out request National grid ole replacement unable to respond due to invalid address

Thursday March 10th

- Received a call from the mayor that a resident from 244 west shore had called her left a message that he had flushed the fire hydrant on west shore rd. The mayor then notified the sheriff dept. to investigate the claim and no evidence was found.

Wednesday March 16th

- Met with the mayor at the village hall for a conference call with the EPA,NYS DOH and Lamont engineering.

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED..
COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF
CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14TH & INDEPENDENCE AVE. SW,
WASHINGTON, D.C. 202500410 (518) 895-2100 202500410 (518) 895-2100 TDD# 1-
800-662-1220**