

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main St. PO box 235
Delanson, New York 12053

Period of June 1, 2022 – June 30, 2022

Total Amount of Water Used per Period:	1,269,000 gals.
Average Amount of Water Used per Day:	42,000gals.
Total Amount of Hypochlorite Used per Period:	37 gals.
Average Amount of Hypochlorite Used per Day:	1.23 gals.

Wednesday, June 1st, 2022:

- Checked valve boxes during milling on 395.
- Received notification from Lamont that he had received my THM/HA5 test results that were sent in to the EPA.

Thursday, June 2nd, 2022:

- Checked valve boxes during milling on 395.
- Registered and took online recertification classed towards my renewal of the water operations license.

Friday, June 3rd, 2022:

- Received a call from a village resident that the valve boxes on 395 and west shore were damaged. Notified Department of health and scheduled a meeting for Monday.

Monday, June 6th, 2022

- Spoke with Chad Corbet from NYSDOT, set up a meeting to meet with him and new castle paving to look at the damage that was done to the valve boxes on Main Street.

Tuesday, June 7th, 2022:

- Meet with DOT and new castle paving in the village, to look at damage done to valve boxes. Resolve: new castle paving agreed to replace 2 valve box extensions. DOT will contact with Schenectady county highway department to clean out valve boxes on Main Street.

Thursday, June 9, 2022:

- Received notification from the clerk with a complaint on a water bill from a resident on thousand acre road. With concerns on the Water quality issues, especially during and after flushing hydrants.

Friday, June 10, 2022

- Received 2nd quarter results for disinfection byproduct's form Jh. Sent them to Lamont engineering who forwarded them to the EPA.

Sunday June 12th, 2022

- Notified the Mayor that I will be out of town for the total of 6 days, notified NYRW to watch the water plant for the total of 6 days, I left contact info.

Tuesday, June 14th, 2022

The Mayor did interview for the assistant water comm. position. I was unable to attend.

Thursday June 16th, 2022

- Received a message on 331 thousand acre rd., as they had very low water pressure. Notified 2 operations from NYRW to do pressure readings on the system and also check the water plant. They stated that everything was normal and they left a message with the homeowner.

Friday June 17th, 2022:

- Homeowner from 331 thousand acer rd. called me and stated that the pressure was still bad and the problem still existed.

Saturday June 18, 2022:

- Responded to 331 thousand acre rd., meet with the homeowner and found the problem. Schenectady county highways while mowing the edges of the rd. hit the valve box, bending the valve box rod. This resulted in turning the water half way off. Was able to do a temporary repair to the water valve box to get the water turned on all the way. I Explained to the homeowner what had happened.

Monday, June 20, 2022

- Met with the mayor to do a 2nd interview for the assistant water comm. position.

Tuesday June 21, 2022

- Met with the mayor for a 3rd interview for the assistant water comm position.

Wednesday June 22nd, 2022

- Went to the water plant to find broken chlorine lines from the injection pump. replaced chlorine line and replaced O- Ring and multi-injection valve.

Friday June 24, 2022

- Received a mark out request from dig safely across from Mudge rd. on Route 20.
-

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED.
COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF
CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14TH & INDEPENDENCE AVE. SW,
WASHINGTON, DC 202500410 (518) 895-2100 TDD#3 1-800-662-1220**