

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main St. P.O. Box 235
Delanson, New York 12953

Period of Sept 1, 2022 – Sept 30, 2022

Total Amount of Water Used per Period: 1,119,000
Average Amount of Water Used per Day: 33,000
Total Amount of Hypochlorite Used per Period: 39.75
Average Amount of Hypochlorite Used per Day: 1.39

Saturday September 3rd

- Cleaned filter bed number 2

Wednesday September 7th

- Called in mark out request for hydrant repair on Railroad Ave in front of Harvest Homes.

Thursday September 8th

- Called carver sand and gravel for approved filter bed sand, I asked him to send Sieve analysis.

Monday September 12th

- Received Sieve analysis report from carver.

Tuesday September 13th

- Received a discolored water complaint from Thousand Acre Rd, I responded to the resident via email.

Wednesday September 14th

- Nick and I repaired fire hydrant on Railroad Ave in front of Harvest Homes.

Thursday September 15th

- Left a message with JH Consulting. I sent Sieve analysis report to him for approval.

Wednesday September 21st

- JH consulting called back, said that the sand will and he will send results to the health department for approval.

Thursday September 22nd

- Sent in monthly Bac- T samples to JH consulting

Friday September 23rd

- Received Bac-T results from JH consulting

Wednesday September 28th

- Received written estimate for a hydrant replacement. Valve and valve box and fittings needed to replace the fire hydrant. Also received estimate for hydrant locks.

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED..
COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF
CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14TH & INDEPENDENCE AVE. SW,
WASHINGTON, D.C. 202500410 (518) 895-2100 202500410 (518) 895-2100 TDD# 1-
800-662-1220**