

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main St. P.O. Box 235
Delanson, New York 12953

Period of April 1, 2023 – April 30, 2023

Total Amount of Water Used per Period: 1,168,000
Average Amount of Water Used per Day: 38,000
Total Amount of Hypochlorite Used per Period: 18.5 Gal
Average Amount of Hypochlorite Used per Day: .59 Gal

Sunday April 2nd:

- Received a call from the mayor, water is running down the sidewalk of main street.
- Responded, checked and verified that it was a water break.

Monday April 3rd:

- Called New York Rural Water to correlate the break area to help pin point the exact location because of new black top on Main Street.

Tuesday April 4th

- Rural water marked out break on main street
- Called Carver to coordinate repair of the break.

Wednesday April 5th

- Sent out notification to village residence of water main break and impacted areas.
- Carver staged equipment.
- Notified local health department of water main break.

Thursday April 6th

- Carver began fixing the break
- Break repaired on Main Street, turned water back on to flush the mains. I found water to be coming up on the intersection of Railroad Ave, and Main Street.
- Carver dug up the road and found bolts to hold 6 in shut off valve to have rotted out and the top of the valve blew the gasket. I called the health department to notify them of a second leak.
- Notified residence on Railroad Ave and Rose Street of second break. The break was also added to the village website.

Friday April 7th

- Updated residence that the break was repaired and the pressure was normal, also notified the local health department.

Tuesday April 11th

- Received a call from Stewart Lane inquiring when the lawn would be repaired after working on water mains.

Wednesday April 12th

- Received a call for a broken piece of sidewalk and dirty sidewalk on Main Street where the break was repaired.
- Called Carver, they responded and repaired the broken sidewalk and also cleaned it.

Thursday April 13th

- Break areas at 157 Stewart Lane, 187 Stewart Lane, and 203 Stewart Lane, lawns were cleaned, rocks and debris removed and topsoil added to all 3 lawns.

Friday April 14th

- Ordered more chlorine from Slack chemical.

Thursday April 27th

- Called Carver to ask them to itemize water main break bill.

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED..
COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF
CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14TH & INDEPENDENCE AVE. SW,
WASHINGTON, D.C. 202500410 (518) 895-2100 202500410 (518) 895-2100 TDD# 1-
800-662-1220**