

Jeffrey A. Iveson  
Water Commissioner, Village of Delanson  
1797 Main St. PO box 235  
Delanson, New York 12053

---

**Period of May 1, 2023 – May 31, 2023**

Total Amount of Water Used per Period: 1,307,000 gals.  
Average Amount of Water Used per Day: 42,000gals.  
Total Amount of Hypochlorite Used per Period: 25 gals.  
Average Amount of Hypochlorite Used per Day: .80 gals.

Monday, May 8th, 2023:

- Sent out monthly BAC-T samples to JH

Monday, May 15th, 2023:

- Cleaned filter bed #3

Wednesday, May 19th, 2023:

- Cleaned filter bed #2

Thursday, May 20<sup>th</sup>, 2023:

- Flushed hydrants in village.
- Boarded up windows at old chlorine station.

Thursday, May 25th, 2023:

- Met insurance company at the plant for a walk thru.

Monday, May 29th, 2023:

- Low water complaint at 377 East Shore road, I went and saw the resident and the resident stated that the water was normal the that time.
- 

Tuesday, May 30<sup>th</sup>, 2023:

- Called the health department to finalize the annual quality report.
- Received a call from DOT about scheduled work on culvert under 395 that feeds the reservoir. I advised we need plans on scope of work and scheduling.

---

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED.  
COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF  
CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14<sup>TH</sup> & INDEPENDENCE AVE. SW,  
WASHINGTON, DC 202500410 (518) 895-2100 TDD#3 1-800-662-1220**