Jeffrey A. Iveson Water Commissioner, Village of Delanson 1797 Main St. P.O. Box 235 Delanson, New York 12953

Period of Sept 1, 2023 - Sept 30, 2023

Total Amount of Water Used per Period: 1,091,000 Average Amount of Water Used per Day: 36,000 Total Amount of Hypochlorite Used per Period: 47 Average Amount of Hypochlorite Used per Day: 1.5

Friday September 1st

• Called the fire chief for use of pump and hoses for the re-sanding process.

Saturday September 2nd

• Received more brown or discolored water complaints which continued throughout the month.

Tuesday September 5th

- Received lab results back from JH, the iron and manganese levels are high causing discolored water.
- I reached out to the health department to inform them of the iron and manganese levels and that they were elevated.
- I also spoke to Lamont engineering about the results and he advised the health department to draft a letter to village residence explaining the situation.

Wednesday September 6th

- I spoke again with a chemist at slack chemical about the elevated iron and Manganese levels to see what he recommended to help remediate the situation.
- Received THM and HA5 results

Tuesday September 12th

• Request from Casey Leclair for all lab work from the water dept.

Wednesday September 13th

• Received a phone call from DEC wanting to come out and sample the upper and lower reservoir.

THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED.. COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF CIVIL RIGHTS, ROOM 326W, WHITTEN BUI;DING, 14TH & INDEPENDENCE AVE. SW, WASHINGTON, D.C. 202500410 (518) 895-2100 202500410 (518) 895-2100 TDD# 1-800-662-1220