

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main St. P.O. Box 235
Delanson, New York 12953

Period of OCT 1, 2023 – OCT 31, 2023

Total Amount of Water Used per Period: 1,180,000Gal
Average Amount of Water Used per Day: 38,000Gal
Total Amount of Hypochlorite Used per Period: 36.5Gal
Average Amount of Hypochlorite Used per Day: 1.17Gal

Monday Oct 2nd

- Seward sand and gravel sent back a quote to Lamontt Engineering (Low bidder on filter sand) asking if accessible with tractor trailer to cut back on delivery costs. Lamontt also verified sand meets specs and could be used for re-sanding the filter plant. The Order was placed for 250 tons of filter sand.

Thursday Oct 5th

- Dig safe mark out request / National Grid 180 West shore rd.

Friday Oct 6th

- Water complaint from Atkins Residence Thousand Acre rd.

Tuesday Oct 10th

- Dig safe mark out request for Duanesburg Churches Rd, contractor replacing retaining wall. I called the contractor.

Monday Oct 16th

- Dig safe mark out request Duanesburg Churches Rd, I called the contactor and the job was cancelled.

Tuesday Oct 17th

- Dig safe mark out request Schenectady county highway, East shore Rd. I marked out the water lines for ditching.

Wednesday Oct 18th

- Sent monthly water samples/ Results from JH lab

Thursday Oct 19th

- Picked up parts for 639 Main Street for new water service.

Friday Oct 20th

- Reached out to Seward sand and gravel to find out when the sand deliveries would start.

Tuesday Oct 24th

- 5 loads of sand delivered.
- also installed new water tap for 639 main street

Saturday Oct 28th

- Picked up water pump from the Fire Department, the pump does not run and is missing parts. I am working on getting the pump running for the re-sanding filter sand process.

Monday Oct 30th

- Ordered parts to rebuild the UV chamber.

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED..
COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF
CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING, 14TH & INDEPENDENCE AVE. SW,
WASHINGTON, D.C. 202500410 (518) 895-2100 202500410 (518) 895-2100 TDD# 1-
800-662-1220**