

Jeffrey A. Iveson
Water Commissioner, Village of Delanson
1797 Main St. P.O. Box 235
Delanson, New York 12053

Period of Oct.1, 2024 – Oct. 31, 2024

Total Amount of Water Used per Period:	1,014,000gals.
Average Amount of Water Used per Day:	33,000 gals.
Total Amount of Hypochlorite Used per Period:	32.5 gals.
Average Amount of Hypochlorite Used per Day:	1.04 gal

- Tuesday Oct 1st
Cleaned filter bed 2
- Oct 8th
Received monthly bac –t from J H labs
- Dig safe request from Northfolk Southern Cole rd RR crossing
- Sunday Oct 20th. Shut down water pump from contractor pumping down lower reservoir
- Met with contractor at lower reservoir had him shut down pump again and called for a meeting with contractor and Dot.
- Thursday Oct 28th had a meeting with D A Collins and dot. at lower reservoir followed up by phone conversation with local health Dept.

**THIS IS AN EQUAL OPPORTUNITY PROGRAM. DISCRIMINATION IS PROHIBITED.
COMPLAINTS OF DISCRIMINATION MAY BE FILED WITH USDA DIRECTOR, OFFICE OF
CIVIL RIGHTS, ROOM 326W, WHITTEN BUILDING. 14TH & INDEPENDENCE AVE. SW,
WASHINGTON, D.C. 202500410 (518)895-2100 YDD# 1-800-662-1220**